

**SPECIAL ADMINISTRATIVE BOARD OF THE TRANSITIONAL SCHOOL****DISTRICT OF THE CITY OF ST. LOUIS**

Purchasing Department
801 North 11th Street
Saint Louis, Missouri 63101

RFP# 003-1617**Sumner Gym Floor Replacement****ADDENDUM No. 1 –Questions and Answers**

1) PAGE 19, 2.1 MATERIALS does not list resilient shock pads but PAGE 20, 3.1 2.a. lists "The underside of first layer shall have resilient pads attached 12" on center...". Please verify if you would like a resilient shock pad under the 1st layer of plywood with the floor system and the thickness of this. Recommended due to height constraints would be 1/2" thickness.

Bleachers may be installed at a later date. 70D durometer pads under the bleachers in the extended position will be required on the north side of the floor.

2) Is there a game line layout and/or details on the bulldog logo referenced to be painted in center circle? If not, please release an electronic format (.jpeg, .ai, .eps, etc.) of the logo or let us know the approximate size and number of colors to include for the logo (ex. 4'x8' w/ 3 colors).

The layout is the current layout that is there now.



3) PAGE 6, 3.14 references a "Purchasing Card" for payments. Is this a direct deposit system or making payments with a credit card?

The District does not use "Purchasing Card" anymore.

4) I don't see a reference list form in the documents for your review of each bidder. We would recommend this to be added for your benefit to verify the bidders are familiar with the project scope and magnitude based off previous performance. A reference list is mentioned in the front end documents but does not list for anything to be submitted with the bid.

It states under 5.2.3.2 References (other school districts where possible)

5) A time frame for the work over winter break was mentioned at the prebid meeting, but I didn't see anything detailed in the documents.

Please provide an anticipated time frame of when the work could be performed for accurate material and labor quotes.

60 days from award of contract

END OF ADDENDUM 1.