



SPECIAL ADMINISTRATIVE BOARD OF THE TRANSITIONAL SCHOOL

DISTRICT OF THE CITY OF ST. LOUIS

Purchasing Department
801 North 11th Street
Saint Louis, Missouri 63101

RFP# 010-1617 District-Wide Energy Efficient Project

Addendum based on the Walk-through

- Seismic loads requirements should be verified with the St. Louis City inspectors. In the past, it has been acceptable to have fixtures supported by cables.
- Stevens and Beaumont should **not** be included in the bid
- The district will accept retrofit fixtures in place of the T8 and T12, in particular to hallways, classrooms and cafeterias.
- Provide alternates for any new fixture replacements that differ from the recommended product requirement found in Table 2 in RFP.

END OF ADDENDUM 4.