



BOARD OF EDUCATION OF THE CITY OF ST. LOUIS
ADDENDUM 4: BID DUE DATE EXTENSION #3 AND QA

January 17, 2023

RFP TITLE: District-Wide Exterior Door Alarm System Installation

RFP #: OP003-2223

Potential Proposer,

This communication is to inform you that the District is extending the Bid Due Date and for this RFP from Thursday, February 2, 2023, 10:00 a.m. to **Thursday, February 23, 2023, 10:00 a.m.** The bid opening will be completed via ZOOM. Please see below for the **NEW Zoom Meeting ID and Password** for the bid opening meeting.

Ketra Montgomery is inviting you to a scheduled Zoom meeting.

Join Zoom Meeting

<https://us05web.zoom.us/j/82702733636?pwd=V2FrL3lUSzlGS2EwMkRaUGZNTlRldz09>

Meeting ID: 827 0273 3636

Passcode: gvps9G

Question:

1. Under scope of work item #6 states that the system must deactivate upon fire alarm this will require a fire alarm relay for each power supply above the doors from your fire alarm vendor. I believe the fire alarms are being changed out or will be in the future at most of the schools through a separate project. Would this be excluded from this project? If not we would need the name and contact of all fire alarm vendors in the District to give numbers on adding relays, etc. and this may not be possible with the on-going work?

Response: Due to different system designs requiring a different number of relays, bidder is responsible to include all fire alarm interconnect to interface the delayed egress system with the fire alarm panel in each location according to code. There are no extras or allowances to this.

Bidders must research and acknowledge that all fire alarm interconnection requirements to the delayed egress system and have included all cost for meeting all applicable code as Change Orders in the situation will not be approved.

End of Addendum 4.