



BOARD OF EDUCATION OF THE CITY OF ST. LOUIS

RFP TITLE: Yeatman Boiler Replacements

RFP# OP020-1920

Addendum #1

This Addendum is to advise all bidders for RFP OP020-1920, the Scope of Work has changed. Below is the revised Scope of Work and must be included in your proposal. The changes that were made are listed below.

Boiler Replacements @ Yeatman

- 1. Regarding the BAS system of the boilers; the Tridium retrofit should be submitted as an alternate bid.**
- 2. The new equipment in contractor proposals should be combatable with the current automation systems.**
- 3. The awarded contractor shall be responsible for the commissioning and start-up and retro-fit of the new boilers regarding the current automation systems.**
- 4. The alternate bid proposal for the Tridium system should include; front end software and commissioning; and any necessary measures to retrofit the current automation system on viewing capabilities of critical boiler components.**

End of Addendum