

**Peabody Elementary School (Initial Site Visit)**  
**1224 South 14<sup>th</sup> Street**  
**St. Louis, Missouri 63104**

**Date of Sampling: June 28, 2016**

**Number of Samples Collected: 8**

**Number of Samples > 20 ppb: 1**

**Number of Samples > 10 ppb: 1**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01	Sink	Kitchen	1.0 ppb	31.8 ppb	Priority 1
02	Fountain	Cafeteria	1.0 ppb	5.9 ppb	Priority 3
03	Fountain	Cafeteria Hall South	1.0 ppb	2.0 ppb	Priority 3
04	Fountain	Cafeteria Hall North	1.0 ppb	1.2 ppb	Priority 3
05	Fountain	1st Floor South	1.0 ppb	12.8 ppb	Priority 2
06	Fountain	2nd Floor North	1.0 ppb	4.0 ppb	Priority 3
07	Fountain	3rd Floor South	1.0 ppb	< 1.0 ppb	Priority 3
08	Fountain	3rd Floor North	1.0 ppb	6.0 ppb	Priority 3

**Peabody Elementary School 2nd (Follow-Up Site Visit)**  
**1224 South 14<sup>th</sup> Street**  
**St. Louis, Missouri 63104**

**Date of Sampling: July 8, 2016**

**Number of Samples Collected: 7**

**Number of Samples > 20 ppb: 0**

**Number of Samples > 10 ppb: 2**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01 (Re-Sample of Sample #01)	Sink	Kitchen	1.0 ppb	10.3 ppb	Priority 2
02 (Re-Sample of Sample #02)	Fountain	Cafeteria	1.0 ppb	5.3 ppb	Priority 3
03 (Re-Sample of Sample #03)	Fountain	Outside Cafeteria South	1.0 ppb	2.6 ppb	Priority 3
04 (Re-Sample of Sample #05)	Fountain	1st Floor South	1.0 ppb	2.8 ppb	Priority 3
05 (Re-Sample of Sample #06)	Fountain	2nd Floor North	1.0 ppb	11.6 ppb	Priority 2
06 (Re-Sample of Sample #08)	Fountain	3rd Floor North	1.0 ppb	8.0 ppb	Priority 3
07 (Re-Sample of Sample #07)	Fountain	3rd Floor South	1.0 ppb	1.3 ppb	Priority 3