Shenandoah Elementary School (Initial Site Visit) 3412 Shenandoah Avenue St. Louis, Missouri 63104

Date of Sampling: June 28, 2016

Number of Samples Collected: 7

Number of Samples > 20 ppb: 2

Number of Samples > 10 ppb: 0

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01	Fountain	2 nd Floor West	1.0 ppb	61.3 ppb	Priority 1
02	Fountain	1 st Floor West	1.0 ppb	8.5 ppb	Priority 3
03	Fountain	Cafeteria High	1.0 ppb	4.8 ppb	Priority 3
04	Fountain	Cafeteria Low	1.0 ppb	1.6 ppb	Priority 3
05	Sink	Kitchen	1.0 ppb	9.4 ppb	Priority 3
06	Fountain	Library High	1.0 ppb	30.5 ppb	Priority 1
07	Fountain	Library Low	1.0 ppb	5.3 ppb	Priority 3

Shenandoah Elementary School 2nd (Follow-Up Site Visit) 3412 Shenandoah Avenue St. Louis, Missouri 63104

Date of Sampling: July 8, 2016

Number of Samples Collected: 8

Number of Samples > 20 ppb: 2

Number of Samples > 10 ppb: 2

Sample	Sample	Sample	Reporting	Result	Priority
ID #	Source	Location	Limit		
01 (Re- Sample of Sample #01)	Fountain	2 nd Floor West	1.0 ppb	38.2 ppb	Priority 1
02	Fountain	2 nd Floor East	1.0 ppb	9.2 ppb	Priority 3
03 (Re- Sample of Sample #02)	Fountain	1 st Floor West	1.0 ppb	64.3 ppb	Priority 1
04 Re- Sample of Sample # 07)	Fountain	Library Low	1.0 ppb	14.1 ppb	Priority 2
05 Re- Sample of Sample #06)	Fountain	Library High	1.0 ppb	5.6 ppb	Priority 3
06 Re- Sample	Sink	Kitchen	1.0 ppb	19.9 ppb	Priority 2

of Sample #05)					
07 (Re- Sample of Sample #03)	Fountain	Cafeteria High	1.0 ppb	1.5 ppb	Priority 3
08 (Re- Sample of Sample #04)	Fountain	Cafeteria Low	1.0 ppb	2.2 ppb	Priority 3

Shenandoah Elementary School 2nd (Re-Sample Basement Fountain) 3412 Shenandoah Avenue St. Louis, Missouri 63104

Date of Sampling: August 7, 2016

Number of Samples Collected: 1

Number of Samples > 20 ppb: 0

Number of Samples > 10 ppb: 1

Sample ID #	Sample Source	Sample Location	Reporting Limit	Result	Priority
01 (Re- Sample of Sample #04)	Fountain	Library Low	1.0 ppb	10.3 ppb	Priority 2