

**Sigel Elementary School  
2050 Allen Avenue  
St. Louis, Missouri 63104**

**Date of Sampling: July 7, 2016**

**Number of Samples Collected: 8**

**Number of Samples > 20 ppb: 5**

**Number of Samples > 10 ppb: 1**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01	Fountain	2 <sup>nd</sup> Floor West	1.0 ppb	33.5 ppb	Priority 1
02	Fountain	2 <sup>nd</sup> Floor East	1.0 ppb	34.5 ppb	Priority 1
03	Fountain	1 <sup>st</sup> Floor East	1.0 ppb	62.3 ppb	Priority 1
04	Fountain	1 <sup>st</sup> Floor West	1.0 ppb	32.4 ppb	Priority 1
05	Fountain	Basement West	1.0 ppb	1.3 ppb	Priority 3
06	Fountain	Basement East	1.0 ppb	16.7 ppb	Priority 2
07	Sink	Kitchen	1.0 ppb	21.6 ppb	Priority 1
08	Fountain	Gym	1.0 ppb	5.6 ppb	Priority 3

**Sigel Elementary School (Re-Sample of Basement East Fountain)**  
**2050 Allen Avenue**  
**St. Louis, Missouri 63104**

**Date of Sampling: August 7, 2016**

**Number of Samples Collected: 1**

**Number of Samples > 20 ppb: 0**

**Number of Samples > 10 ppb: 0**

<b>Sample ID #</b>	<b>Sample Source</b>	<b>Sample Location</b>	<b>Reporting Limit</b>	<b>Result</b>	<b>Priority</b>
01 (Re-Sample of Sample #06)	Fountain	Basement East	1.0 ppb	4.6 ppb	Priority 3